

**Naval Hospital Bremerton  
Interim Life Safety Risk Assessment**

**Project Number:** \_\_\_\_\_ **Title:** \_\_\_\_\_

**Project Manager:** \_\_\_\_\_ **Date:** \_\_\_\_\_

This risk assessment is used to identify and document required interim life safety measures. This assessment must be performed and adhered to for all facility work and must be filled out, signed and retained in the project file for facility projects. If the answers to any questions are yes, consult with NHB Life Safety Officer to determine necessary Interim Life Safety Measures ILSM(s).

**Y N** Will the project affect a fire exit or other means of egress?

**Y N** Will the affected exits be used by anyone other than project contractor personnel?

**Y N** Will the project obstruct building access for emergency responders?

**Y N** Will the project obstruct construction area access for emergency responders?

**Y N** Will the project impair the operation of the fire alarm, detection or suppression systems?

**Y N** Will the project require a fire alarm, detection or suppression systems outage lasting more than 4 hours for any 24 hour period?

**Y N** Will the project involve temporary construction partitions?

**Y N** Will the project involve the storage or use of flammable or combustible material?

**Required ILSM(s)**

Temporary fire protection systems: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Additional firefighting equipment: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Additional fire prevention and response training for construction and/or hospital personnel: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

