

**Naval Hospital Oak Harbor  
Preconstruction Risk Assessment (cont'd)**

**Y N** Will project generate noise or vibration levels that will interfere with patient care?

*If yes, coordinate with Safety Division and Industrial Hygiene Department to identify noise reduction strategies.*

**Y N** Will project involve work in a confined space?

*If yes, workers must follow OSHA requirements for confined space entry.*

**Y N** Will project involve the use of cranes?

*If yes, coordinate with crane safety specialist, NASWI Safety Office.*

**Y N** Will the project impact air quality, for example, by the release of fugitive emissions such as dust, mist, fumes or vapors such as Volatile Organic Compounds?

*If yes, consult with the Safety Division to determine protective measures for workers, hospital staff and patients.*

**Emergency (Disaster) Procedures:**

**Y N** Will the project impede the hospital's emergency response plans or procedures, such as decontamination, mass casualty, access to emergency equipment or materials or access to emergency operations center?

*If yes, consult with the Emergency Manager to determine and institute interim measures and procedures.*